

Ministry of Industry and Trade



Implemented by



ERAV



SGREEE - AA1: Revision of Viet Nam's Smart Grid Roadmap

Task 1. A Comprehensive Assessment of Smart Grid Development in

Vietnam

TABLE OF CONTENTS



Regulatory Development for Vietnam Smart Grid Roadmap



Power Development Plan VIII (Draft of November 2021)



Annual Summary Report of Viet Nam's Smart Grid Development



Vietnam Smart Grid Index Assessment







2. Power Development Plan VIII (Draft of November 2021)

WHEELER A

National electricity demand forecasting



National grid's maximum capacity



Transmission system construction, by period



Thursday, March 10, 2022

2030 2045 2025 Upper bound Upper bound Upper bound 6.50% 17.90% 7.80% 7.60% 5.90% 16.80 8.40% % 24.00 60.60 % 61.40 1% 9.80% % % 69.80 % 2.50% Lower bound Lower bound Lower bound 5.60% 5.40% 7.80% 15.70% 7.30% 15.40 % 8.40% 23.20 1% 8.20% % 61.70 65.50 2.20% % 72.70 % % Wind Solar Hydro Other renewable Other

Renewable energy proportion in total electricity production

Thursday, March 10, 2022

CO2 emission and Power dispatching



Reformation of power dispatching organization

- 2021 2025: National power system dispatching center (NLDC) of EVN will become a one-member limited liability company (NSMO), wholly state-owned. Coincide with introduction of retail energy market
- 2026 2030: NSMO separates from EVN.
 The electricity market expands with derivative market, demand response, etc.
- 2031 2045: Vision for a multi-sector utility service.

3. ANNUAL SUMMARY REPORT OF VIETNAM'S SMART GRID DEVELOPMENT

Annual Summary Report (2012-2016/2017)

First phase (2012-2016) and 2017 Reports

Categories	2012-2016	2017			
SCADA Connection	 Increase percentage of SCADA system connection in power plants and substations Unconnected 110 kV substations (41/703 substations) Percentage of stable and sufficient connection needs improvement (objective is over 80%, >30MW power plant is 76%, 500/220/110kV sub is 76%, 78%, 81%, 73% respectively) 	 Increase percentage of SCADA system connection in power plants and substations. All but the percentage of stable and sufficient connection of 110kV substations (77%) exceed 80% threshold. 			
Remote Data Collection	Basic Complete (EVNNPC at 86%)	Complete			
Measuring Equipment Installation	Complete	Complete			
Digital Meters	As of 12/2016, 10% increase of digital meter, 5% increase of digital meter with remote measuring capability installed nationally compared to 12/2015.	Digital meters without and with remote capability grew by 7% and 6% respectively, now at 35% and 26.5% of total number of meters.			
Power Supply Reliability	 MAIFI: 1.51 (times/customer) SAIDI: 1651 (minutes) SAIFI: 10.60 (times/customer) 	 MAIFI: 2.40 (times/customer) SAIDI: 1183 (minutes) SAIFI: 10.70 (times/customer) 			

2018 and 2019 Reports

Categories	2018	2019		
SCADA Connection	 The percentage of power plants and substations equipped with SCADA and sufficient signals remained at a high level and improved in comparison with that in 2017. The percentage of power plants with capacity larger than 30MW that has sufficient signals is more than 80%, while the figure of 500/220kV substations is larger than 87%. 	 The percentage of power plants and substations equipped with SCADA and sufficient signals remained at a high level and improved in comparison with that in 2018 The percentage of power plants with power generation capacity of above 30MW, 500/220kV substations equipped with SCADA and sufficient signals exceeded 90%; the percentage of 100kV substations with sufficient signals reached 70%, which was substantially improved in comparisonn with that in 2018 (63%). 		
Remote Data Collection	Complete	Complete		
Measuring Equipment Installation	Complete	Complete		
Digital Meters	Quantity of digital meters: increasing by approximately 6% over the respective statistics of December 2017. Quantity of digital meters which <i>applied remote metering</i> and data collection increasing by approximately 9% over the respective statistics of December 2017.	Quantity of digital meters: increasing by approximately 11% over the respective statistics of December 2018. Quantity of digital meters which <i>applied remote metering</i> and data collection increasing by approximately 7% over the respective statistics of December 2018		
Power Supply Reliability	 MAIFI: 0.78 (times/customer) SAIDI: 724 (minutes) SAIFI: 4.97 (times/customer) 	 MAIFI: 0.89 (times/customer) SAIDI: 1071 (minutes) SAIFI: 6.57 (times/customer) 		

Thursday, March 10, 2022

2020 Report

SCADA Connection Rate

Power Plant / Substation	Year		Total Amount	Connected	Remaining connection	Connected and sufficient signals
	12/2019	Quantity	222	222	216	199
Power Plant		%		100%	97%	90%
(> 30MW)	12/2020		276	276	270	245
	12/2020			100%	98%	89%
	12/2010	Quantity	32	32	32	29
Substation	12/2019	%		100%	100%	91%
500kV	12/2020		36	36	36	33
				100%	100%	92%
	12/2019	Quantity	134	134	134	132
Substation		%		100%	100%	98,5%
220kV	12/2020		140	140	138	139
				100%	99%	99%
	12/2019	Quantity	841	806	763	609
Substation		%		96%	91%	72,4%
110kV	12/2020		869	844	825	756
				97%	95%	87%

Thursday, March 10, 2022





Thursday, March 10, 2022

2020 Report

Unmanned Substation

Unit	Number of Control Center in Operation	Number of Control Center in Operation / Total amount of Control Centers	Number of Unmanned Substations in Operation (220/110kV)	Total number of operating substations (220/110kV)	Unmanned Substations in Operation / Total number of operating substations (220/110kV)
EVNNPC	27	100%	213	269	79%
EVNCPC	13	100%	123	123	100%
EVNSPC	21	100%	230	230	100%
EVNHANOI	01	100%	47	48	98%
EVNHCMC	01	100%	55	55	100%
EVNNPT	T No Control Center		94	129	73%

2020 Report

SAIDI & SAIFI

Reliability Criteria	SAIDI (minutes)	SAIFI (times/customer)
2019	1.071	6,57
Target for 2020	400	8
Result for 2020	356	3,11

The SAIDI and SAIFI indexes of the Power Corporations and the whole EVN exceeded the plan set out in Decision No. 1047/QD-BCT dated March 21, 2016, of the Minister of Industry and Trade on approving the set of criteria to assess the development level of Vietnam's electricity industry

Thursday, March 10, 2022





Thursday, March 10, 2022

Monitoring & Control

	EVNHCMC		EVNCPC		EVNSPC
 All 220/110kV sub equipped with SCA Applications: Fault location Fault isolation Automated feeder reconfiguration Distribution powe Load and Volt/VAF Planned outage st Short circuit calcul X Does not have too minimizing grid los forecasting 	All 220/110kV substations are equipped with SCADA Applications: Fault location Fault isolation Automated feeder reconfiguration Distribution power flow	✓ ✓ •	 MV Network is monitored by SCADA, but LV Network does not have that feature. Applications: Grid Topology Management, Power flow calculation short circuit calculation Random error analysis 	✓ ×	MV Network is monitored by SCADA, but LV Network does not have that feature. EVNSPC does not have tools for state estimator, load flow, minimizing grid losses and load forecasting.
	Planned outage study	• power flow optimization optimization of capacitors		EVN HNPC	
	Short circuit calculation Does not have tools for minimizing grid losses and load forecasting	• • ×	 allocation open-loop optimization Protection settings management Load estimation and load forecasting Does not have any tools for load shedding and managing the voltage 	~	Uses a SCADA system to monitor the MV network, but it is not used to monitor the LV network. EVNHNPC integrated Volt-VAR control, Load Shedding Fault Management and System Restoration to their SCADA system

Data Analytics

Table: Digital Meter Roll-out per regions

Region	Digital Meter Roll-out [%]		
Ho Chi Minh	82%		
Central	92%		
Southern	41%		
Ha Noi	100%		

- The smart meters installed in Viet Nam can measure active and reactive power consumed or produced by the prosumer. The customer can monitor his/her energy consumption with 30 minutes steps via a mobile app or webpage. The digital meters installed can measure the power factor but can't measure harmonic distortion.
- Unfortunately, the data collected by smart meters are not used for network planning and maintenance and asset renewal but is used for load forecasting. The current digital meters installed don't offer demand response or load control service. Moreover, it neither detects outages nor non-technical losses.

Supply Reliability

Linit	Voor	MAIFI	SAIDI	SAIFI
Unit	Tear	(times)	(times)	(times)
	2019	1,08	2495	14,3
EVNNPC	Plan for 2020	2	511	9
	Result for 2020	0,46	498	4,68
	2019	1,2	297	2,69
EVNCPC	Plan for 2020	2,15	402	8,73
	Result for 2020	1,17	362	2,33
	2019	0,79	275	2,3
EVNSPC	Plan for 2020	2	306	5,27
	Result for 2020	1,28	287	2,73
	2019	0,44	205	1,45
EVNHANOI	Plan for 2020	2	254	6,12
	Result for 2020	0,26	173,5	1,3
	2019	0,37	58,46	0,77
EVNHCMC	Plan for 2020	2	174	5
	Result for 2020	0.35	44,2	0.59
	2019	0,89	1071	6,57
EVN	Plan for 2020	2	400	8
	Result for 2020	0.77	356	3,11

Thursday, March 10, 2022

Supply Reliability

- All the DSOs in Vietnam monitor the SAIDI and SAIFI indexes in their network according to Circular 39/2015/TT-BCT. It has been noticed from the SAIDI and SAIFI reports that it improves year after another except for EVNNPC in which SAIDI and SAIFI values increased in 2019.
- All the DSOs in Vietnam monitor the voltage deviation in the network. It has been noted from the survey that whenever a voltage deviation occurs in the network, even if it is for a couple of minutes, the DSO calculate the whole hour as a voltage out of range, which could wrong sign. Therefore, it is recommended to calculate the voltage deviation beyond the limit with minutes not with hours.

DER Integration

Regarding Renewable Energy Integration Regulation currently defines the integration of renewable energy but not yet consider the RE Ancillary Services.

Regarding Energy Flexibility The energy flexibility is still under development in Vietnam and there is no clear regulation defining it

It is recommended to accelerate the issue of new regulations defining the operation of batteries and power-to-gas technology to support the electric energy system with a high percentage of renewable energy integration

Green Energy



Power generation mix in Viet Nam

It is recommended to continue the promotion of electric mobility and develop regulations to support smart charging and vehicle-to-grid technology.

Cyber Security



 VPN and PAM are used to access remote hardware and devices

Important Notes:

- The software used are updated every quarter or whenever it is recommended by the manufacture.
- Decision No. 99/QD-EVN regulators data security.
- Annual training and audits are organized on annual basis.
- All units of EVN (except EVNEPTC) have registered and achieved cybersecurity certificate according to ISO 27001.

Customer Empowerment & Satisfaction

- Energy consumption can be monitored by customers with remote meters
- Large customers could join demand response campaign voluntary without receiving any incentives. It is recommended in the future to organise a demand response market to customers who will participate in demand response.
- The utilities organise annual surveys to get feedback from customers. The survey results show very good feedback from the customers.

Thank you!

Thursday, March 10, 2022